

ATI 2015 - 70th Conference of the ATI Engineering Association

Analysis of CO₂ post-combustion capture in coal-fired power plants integrated with renewable energies

Roberto Carapellucci^{a,*}, Lorena Giordano^b, Maura Vaccarelli^a^a*Department of Industrial and Information Engineering and Economics, University of L'Aquila, Via G. Gronchi 18, 67100 L'Aquila, Italy*^b*Laboratoire Réactions et Génie des Procédés (LRGP) (UMR 7274), Université de Lorraine, ENSIC, 1, rue Grandville – BP 20451, 54001 Nancy Cedex, France*

Abstract

In light of the current consumption and proven reserves of fossil-fuels, it is beyond doubt that they will continue to play an important role in the World energy scenario, making crucial the implementation of solutions for carbon emissions reduction. One promising option for decarbonising existing or new-build power plants is post-combustion capture by chemical absorption. Besides its environmental benefits, this process causes a decrease of power plant capacity, due to heat and electricity requirement of CO₂ capture and compression systems. A possible way to overcome this drawback is the use of auxiliary systems based on renewable technologies. In this paper two options for integrating renewable energies into a coal-fired power plant with CO₂ post-combustion capture are investigated. The first one envisages the use of an auxiliary biomass boiler, providing an additional power capacity, besides satisfying the CO₂ capture heat requirement. In the second option, a concentrating solar power (CSP) system is used to meet part of regeneration heat duty, in place of steam extraction from the main power plant or steam production by a biomass boiler. The study will assess the effect of renewable source availability and energy conversion efficiency on the design of the auxiliary power unit, as well as on the energy performances of coal-fired power plant retrofitted with CO₂ capture.

© 2015 The Authors. Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

Peer-review under responsibility of the Scientific Committee of ATI 2015

Keywords: Carbon capture; Coal; Auxiliary system; Integration; CSP; Biomass.

* Corresponding author. Roberto Carapellucci Tel.: +39 0862 434320; fax: +39 0862 434403.
E-mail address: roberto.carapellucci@univaq.it

1. Introduction

Coal represents the most widely distributed fossil fuel, with proven reserves estimated at around 900 billion tonnes [1]. Currently, coal-based power plants provide more than 40% of global electricity production and it is expected they will remain a key technology in meeting the future energy needs, especially in developing countries [2]. Nevertheless, these plants also account for over 28% of CO₂ emissions, thus requiring the implementation of carbon reduction measures, in order to mitigate the impact of global climate changes.

Post-combustion capture based on amine-scrubbing represents one of the most suitable technique for capturing CO₂ from exhaust flue gas, as it requires minor changes in power plant layout [3]. However, the CO₂ capture retrofit imposes a not negligible loss in power plant capacity, due to the need to extract part of steam for solvent regeneration, as well as to the parasitic power losses of capture and compression units.

In this respect, several options have been studied to reduce the power plant derating, including the integration of an auxiliary unit co-producing heat and electricity. When the combined heat and power (CHP) system is fed by fossil fuels, an additional flue gas stream to be treated is produced, negatively affecting the size and costs of the CO₂ capture island [4]. Using renewable energies in place of fossil fuels to feed the auxiliary unit allows to overcome this issue, besides further reducing the CO₂ emitted per unit of electricity production.

A limited number of studies have addressed the integration of renewable technologies in fossil fuel power plants retrofitted with CO₂ capture. Kang et al. [5] optimized the operation of a coal-fired power plant, integrating a natural gas fired CHP system and a wind turbine to support the heat and electricity requirement of capture island. Some studies assessed the potential benefits of solar assisted post-combustion capture. In this respect, Cohen [6] and Mokhtar [7] evaluated the techno-economic feasibility of integrating a CSP system fulfilling all or part of the reboiler steam requirement. Solar-assisted solvent regeneration was compared by Zhao et al. [8] to the feed-water repowering operated by replacing the high quality steam bleedings with a CSP system based on a parabolic trough collector.

Other researchers investigated the use of a biomass-fired auxiliary unit producing both heat and electricity for the CO₂ capture island, with the aim to assess its effect on energy and economic performances of retrofitting natural gas [9] and coal-fired power plants [10].

Nomenclature

Symbols

CO _{2,em}	Specific CO ₂ emissions, kg/MWh
m	Mass flow rate, kg/s
P	Power, MW
P _{th}	Thermal power to the reboiler, MW _{th}
q _{th}	Reboiler duty, MJ/kg
R _{BIO}	Biomass requirement, ktonne/year

Subscripts

BP	Back Pressure
CS	CO ₂ capture system
CP	Compression
EXH	Exhaust
EXTR	Extraction
S	Steam
SH	Superheated

Greek symbols

η	Efficiency
φ	Capture ratio

Acronyms

BB	Biomass Boiler
BIO	Biomass
CHP	Combined Heat and Power
CSP	Concentrated Solar Power
DNI	Direct Normal Irradiance
IPST	Intermediate Pressure steam turbine
HPST	High Pressure Steam Turbine
LPST	Low Pressure Steam Turbine
LHV	Low Heating Value
PC	Pulverized coal power plant
ST	Steam Turbine

In this study two options for integrating renewable energies into a coal-fired power plant with CO₂ post-combustion capture are investigated. The first one concerns the use of an auxiliary boiler fed by woody biomass, that meets the heat requirement of CO₂ capture system and eventually provides an additional power capacity, by expanding the superheated steam in a back-pressure steam turbine. The second one envisages the integration of a CSP system based on Fresnel technology to produce a fraction of steam for the reboiler operation, while using the conventional steam extraction or steam production from an auxiliary biomass boiler to compensate for the daily variation of solar resource availability.

The heat integration options based on renewable energies are compared to the case of conventional steam extraction operated upstream the low pressure steam turbine of coal-fired power plant. The energy analysis of power system is carried out using the GateCycle software [11], while ChemCad platform [12] is used to simulate the CO₂ capture process based on amine absorption.

2. Pulverized-coal power plant with CO₂ removal system

A 100 MW coal-fired power plant has been selected as study case to investigate the retrofit with a post-combustion CO₂ capture system (Figure 1). At design conditions, the subcritical boiler is fed with a fuel flow rate of 9.4 kg/s, thus producing a superheated steam flow rate of 79.3 kg/s at 540°C and 180 bar. Hence, with a LHV efficiency of 42%, the coal-fired power plant emits 752 kg_{CO2}/MWh. In order to capture 90% of CO₂ from power plant exhausts, a MEA-based absorption system has been added [13]. With a stack flue gas flow rate of 94.2 kg/s and a reboiler duty of 3.5 MJ/kg_{CO2} [14], the thermal power requirement for solvent regeneration states at 65.7 MW_{th}.

In this study, several options for providing heat to the reboiler are compared, including the steam extraction from the power block, operated at crossover pipe between IPST and LPST and the integration of an auxiliary unit based on a biomass boiler or a CSP system.




Figure 1 – Layout of coal-fired power plant with steam extraction for the CO₂ capture system

2.1 Auxiliary unit based on biomass boiler

The boiler auxiliary system, based on a fixed bed technology, burns a woody biomass (LHV=19.0 MJ/kg) with 40% excess of air. Passing through the heat exchange section, the exhaust flue gases are cooled down to 130°C and then vented into the atmosphere, without increasing at first approximation the CO₂ emissions. Indeed, the production of CO₂ from biomass combustion exactly offsets that trapped during the photosynthetic fixation; hence, neglecting the emissions from collection, the only source of CO₂ is that related to the transportation of biomass [9], that has been evaluated assuming a short supply chain (within 70 km from the site of the biomass plant) and the use of heavy duty vehicles with a capacity

of 27 tonnes.

According to the complexity of the system layout, the auxiliary unit only produces the saturated steam ($p_{SH}=3$ bar, $T_{SH}=134^{\circ}\text{C}$) required for the stripping reboiler operation or it also provides an additional power capacity, by expanding the superheated steam ($p_{SH}=80$ bar, $T_{SH}=540^{\circ}\text{C}$) in a back pressure steam turbine (BP-ST).

2.2 Auxiliary unit based on CSP system

The solar field is based on a direct steam generation operated by linear Fresnel collectors of Novatec Solar technology [15]. The base module includes 16 rows of primary mirrors, with a length of 44.8 m and a width of 72 cm, for a total reflective area of around 514 m^2 . The required temperature increment and steam flow rate production is then achieved by properly connecting in series and parallel the base modules.

Table 1. Monthly values of DNI and T_{air} in Brindisi (Italy)

Month	DNI [kWh/m ²]	T_{air} [°C]
January	60.65	9.5
February	72.29	9.9
March	121.11	11.5
April	163.28	14.1
May	202.96	17.9
June	226.32	21.8
July	236.98	24.5
August	223.10	24.8
September	153.09	22.1
October	111.75	18.2
November	66.18	14.1
December	51.19	11.0
Year	1688.91	16.6

Thermal power production of solar collectors has been evaluated as a function of direct normal irradiation (DNI), temperature increase and optical efficiency factor, according to the methodology described in a previous study of the same authors [16].

In order to evaluate the solar resource availability, a software developed at the Department of Mechanical, Energy and Management Engineering (University of L'Aquila) has been used [17]. Considering a potential power plant installation in the city of Brindisi (Italy), direct normal irradiation and air temperature data on an hourly and monthly basis have been estimated (Table 1). Hence, by properly averaging hourly data, five diurnal profiles of DNI and T_{air} have been evaluated, describing a typical day of each season and the mean annual daily behavior.

The solar field has been designed assuming the highest value of DNI (870 W/m^2) and solar height (77.8°), detected on June 21 at noon, an azimuth angle of zero and an ambient air temperature of 30°C . Assuming a series of 10 base modules, an optical efficiency of 67% and a water to steam temperature increase from 110 to 140°C , the thermal power production per line states at 2.7 MW [18]. Hence, in order to provide the whole thermal power required by the reboiler at design conditions, a number of 24 lines in

parallel is required [16].

3. Comparing the energy performances of retrofit options based on renewable energy integration

Assuming that the stripper reboiler heat duty is satisfied by extracting a fraction of steam ($m_{EXTR}=24.9$ kg/s) at the exit of intermediate pressure steam turbine (Case 0), as shown in Figure 1, the coal-fired power plant capacity drastically reduces to 79.1 MW (-21%), also due to the electricity consumption of CO₂ capture and compression units (PCS+PCP =7.4 MW). Hence, the net efficiency reduces of around 9% pts compared to design conditions, stating at 33.1%.

Table 2 – Comparison of heat supply options based on steam extraction and biomass boiler integration

	Design case	Off-design cases with CO ₂ capture ($\phi=90\%$)			
		<i>Case 0</i>	<i>Case 1</i>	<i>Case 2</i>	<i>Case 3</i>
POWER UNIT					
P_{ST} [MW]	100	86.5	100	100	94.3
m_{COAL} [kg/s]	9.4	9.4	9.4	9.4	9.4
m_{SH} [kg/s]	79.3	79.3	79.3	79.3	79.3
m_{EXTR} [kg/s]	-	24.9	-	-	9.5
m_{EXH} [kg/s]	94.2	94.2	94.2	94.2	94.2
CAPTURE UNIT					
P_{th} [MW]	-	65.7	65.7	65.7	65.7
q_{th} [MJ/kg]	-	3.5	3.5	3.5	3.5
P_{CP} [MW]	-	5.5	5.5	5.5	5.5
P_{CS} [MW]	-	1.9	1.9	1.9	1.9
AUXILIARY UNIT					
m_{BIO} [kg/s]	-	-	4.9	3.8	3.1
$P_{BB, th}$ [MW]	-	-	94.9	71.4	58.9
P_{BP-ST} [MW]	-	-	21.2	-	13.2
m_S [kg/s]	-	-	29.8	30.3	18.5
p_S [bar]	-	-	3	3	3
T_S [°C]	-	-	148.4	133.5	148.4
R_{BIO} [ktonne/year]	-	-	134	100	83
P_{NET} [MW]	100	79.1	114	92.8	100
η_{NET} [%]	42.0	33.1	34.1	29.9	33.6
$CO_{2, em}$ [kg/s]	752.0	95.3	66.6	81.7	75.7

In order to overcome these issues, several alternatives for CO₂ capture retrofit have been analyzed:

- **Case 1:** steam from a CHP unit with BB and BP-ST;
- **Case 2:** steam from BB;
- **Case 3:** steam extraction and steam from CHP unit;
- **Case 4:** steam extraction and steam from a CSP system;
- **Case 5:** steam from CHP unit and CSP system.

3.1. Integration of an auxiliary biomass boiler

Table 2 summarizes the simulation results of retrofit options based on a biomass boiler integration. In *Case 1*, the auxiliary system provides both heat and electricity to the CO₂ capture island. If the steam extraction is entirely replaced by the biomass steam production ($m_s=29.8$ kg/s), the power plant capacity increases to 114 MW, due to the additional power produced by the BP-ST ($P_{BP-ST}=21.2$ MW). Compared to *Case 0*, the efficiency penalty is slightly lower (-8% pts), while the specific CO₂ emissions referred to the net power output (P_{NET}) drastically reduces to 66.6 kg/MWh (-30%). With a biomass flow rate of 4.9 kg/s and assuming a power plant capacity factor (CF) of 85%, the corresponding annual requirement states at 134 ktonne/year. Considering the limited availability of woody biomass for the site of interest [19] and with the aim to limit the radius of biomass collection area (lower than 70 km), two potential alternatives have been investigated.

Considering an auxiliary unit layout based on steam production only (*Case 2*), the annual biomass requirement reduces to around 100 ktonne/year ($m_{BIO}=3.7$ kg/s). From the energy point of view, the power plant capacity reduces to 92.8 MW, while the efficiency penalty exceeds 12% pts, due to the production of low grade heat.

Combining the steam production from a CHP auxiliary unit with steam extraction (*Case 3*) allows to further reduce the biomass needs, as well as to mitigate the negative impacts on power plant performances. If the steam production accounts for around 60% ($m_s=18.5$ kg/s) of the overall reboiler thermal power duty, the annual biomass requirement states at 83 ktonne/year ($m_{BIO}=3.1$ kg/s). Due to the power capacity provided by BP-ST ($P_{BP-ST}=13.2$ MW), the power plant derating is eliminated ($P_{NET}=100$ MW), thus leading to an efficiency penalty of around 8% pts ($\eta_{NET}=33.6\%$) and specific CO₂ emissions of 75.7 kg/MWh.

3.2. Integration of a CSP system

According to the solar resource availability, the solar collectors are able to provide part of the steam for solvent regeneration, thus requiring a back-up system to meet the remainder fraction.

In this study two alternatives for assisting the solar steam production have been compared. In the first one (*Case 4*), the CSP system is combined with steam extraction from the coal-fired power plant, assuming a high-pressure steam turbine (HPST) overload of 10%, in order to mitigate the corresponding derating of power capacity; in the second one (*Case 5*), a biomass boiler operating at the pressure required by the stripper reboiler is used to compensate for the variability of solar steam production.

It is noted that the net power plant efficiency has been evaluated accounting for the solar energy transferred to the CSP system, while the heat rate has been referred to the thermal power provided by coal and biomass combustion [20].

In both cases the solar steam production achieves the highest values in the middle of the day (11:00 a.m.), varying between 14.5 kg/s and 24 kg/s for a typical winter and summer day. In these conditions, the CSP system is able to provide more than 50% (winter) and 80% (summer) of the reboiler thermal power requirement.

In *Case 4*, the mean annual capacity derating states at -14%, leading to a yearly electricity production gain of 2.9% compared to the case of conventional steam extraction (*Case 0*). Figure 2a shows that the net efficiency at night is the same as *Case 0*, while it reduces with the increase of solar heat contribution, due to the higher low grade steam production. This effect is even more pronounced during summer, when the net efficiency reaches a minimum value of 30.8% (11:00 a.m.). However, due to the increase of power plant generating capacity, the CSP system allows for a decrease of heat rate, whose maximum extent ranges from -7% (10140 kJ/kWh; winter) to -12% (9618 kJ/kWh; summer). On the other hand, the

specific CO₂ emissions on a mean annual basis slightly reduces to around 93 kg/MWh.

In *Case 5*, the power plant capacity derating drastically reduces to around 7%, being fully ascribed to the power losses for CO₂ capture and compression operations. Increasing the solar energy availability, the net efficiency slightly increases compared to *Case 2* (29.9%), as the solar contribution allows to reduce the biomass fed to the boiler for the steam production; moreover the specific CO₂ emissions weakly reduce up to a minimum value of 81.3 kg/MWh (summer), as the decrease of biomass requirement mitigates the corresponding CO₂ emissions for transport. More noticeable is the benefit on the heat rate,

showing a maximum reduction of around 10% (10653 kJ/kWh) and 20% (9738 kJ/kWh) during a typical winter and summer day. This is related to the decrease of m_{BIO} , that leads to a significant reduction of annual biomass requirement (80.9 ktonne/year) compared to *Case 2*.




Fig.2 .Energy performances of heat supply options based on CSP system combined with steam extraction (a) and biomass boiler (b)

4. Conclusions

This paper has investigated the potential benefits of integrating renewable energies into a 100 MW coal-fired power plant, retrofitted with a CO₂ capture process based on amine scrubbing. Two main options have been analyzed from the energy point of view, basically involving the use of a biomass boiler and a CSP system, producing a fraction of the heat requirement for the solvent regeneration.

Assuming that the thermal power for the stripper reboiler operation is provided by a biomass CHP unit (*Case 1*), the power plant capacity increases of around 14%. The efficiency penalty (-8% pts) compared to design conditions ($\eta_{NET,D} = 42\%$) weakly reduces compared to the case of conventional steam extraction (*Case 0*), while the specific CO₂ emissions passes from 95.3 kg/MWh to 66.6 kg/MWh. If the auxiliary CHP unit is combined with a steam bleeding providing around 40% of the heat duty, the annual requirement of woody biomass drastically reduces to 83 ktonne/year (-38%). With almost the same net efficiency of *Case 1* (33.6%), the power plant derating is eliminated, against an increase of specific CO₂ emissions (75.7 kg/MWh).

Due to the discontinuity of solar energy resource, the integration of a CSP system allows to cover only a fraction of steam required for the solvent regeneration, reaching a maximum value of 80% during summer. If the solar steam production is assisted by a conventional steam bleeding from the power block, the mean annual power plant derating states at -14%; compared to *Case 0*, the net efficiency decreases during the day up to around 31%. However, the steam production from solar collectors also allows for a non negligible reduction of heat rate, reaching a peak value of 12% (9618 kJ/kWh). Combining the CSP system with steam production from a biomass boiler, the mean annual power plant derating further reduces (-7%), against a decrease of net efficiency, being it always lower than 31%. Compared to *Case 2*, this option also allows to drastically reduce the mean annual heat rate, as a result of the decreased biomass requirement (80.9 ktonne/year).

References

- [1] World Energy Council, World Energy Resources 2013 Survey.
- [2] International Energy Agency (IEA), Power Generation from Coal - Measuring and Reporting Efficiency Performance and CO₂ Emissions, Paris, 2010.
- [3] Rubin E.S., Mantripragada H., Marks A., Versteeg P., Kitchin J., The outlook for improved carbon capture technology, *Progr Energ Combust*, 38 (2012) 630-671.
- [4] Bashadi S.O., Herzog H.J., Using auxiliary gas power for CCS energy needs in retrofitted coal power plants. *Energy Procedia* 4 (2011).
- [5] Kang C.A., Brandt A.R., Durlofsky L.J., Optimal operation of an integrated energy system including fossil fuel power generation, CO₂ capture and wind, *Energy* 36 (2011) 6806-6820.
- [6] Cohen S.M.W.M., Rochelle G.T., Utilizing solar thermal energy for solvent regeneration in postcombustion CO₂ capture, ASME 4th International Conference on Energy Sustainability, Phoenix, 2010.
- [7] Mokhtar M., Ali M.T., Khalilpour R. et al., Solar-assisted postcombustion carbon capture feasibility study, *Appl Energy* 2012;92:668-76.
- [8] Zhao Y., Hong H., Zhang X., Jin H., Integrating mid-temperature solar heat and post-combustion CO₂-capture in a coal-fired power plant, *Sol Energy*, 86 (2012) 3196-3204.
- [9] Vaccarelli M., Carapellucci R., Giordano L., The use of biomass to reduce power derating in combined cycle power plants retrofitted with post-combustion CO₂ capture. In: *Proceeding ECOS 2014*, ISBN 978-952-12-3099-8.
- [10] Khorshidi Z., Ho M.T., Wiley D.E., Techno-economic evaluation of using biomass-fired auxiliary units for supplying energy requirements of CO₂ capture in coal-fired power plants. *Int J Greenh Gas Con* 32 (2015) 24-36.
- [11] General Electric Company (2005), GateCycle™, Getting started & installation guide, General Electric Company.
- [12] Chemstations, Process Flowsheet Simulator. User Guide Chemstations Inc., 2008, Houston, USA.
- [13] Vaccarelli M., Carapellucci R., Giordano L., Energy and economic analysis of the CO₂ capture from flue gas of combined cycle power plants. *Energy Procedia* 45 (2014) 1165-1174.
- [14] Carapellucci R., Giordano L., Vaccarelli M., Studying Heat Integration Options For Steam-Gas Power Plants Retrofitted With CO₂ Post -Combustion Capture, *Energy* 85 (2015) 594-608.
- [15] Novatec Solar (2010). Nova 1 - Turnkey solar boiler, mass produced in industrial precision. Novatec Solar GmbH, Karlsruhe.
- [16] Carapellucci R., Giordano L., Vaccarelli M., CO₂ post-combustion capture in coal-fired power plants integrated with solar systems, In: *UIT Heat Transfer Conference 2015*.
- [17] Giordano L., Studio ed ottimizzazione di un'isola energetica da fonti rinnovabili con sistema di accumulo ad idrogeno. PhD Thesis. University of L'Aquila. 2010.
- [18] Cau G., Cocco D., Tola V., Analisi dell'integrazione di impianti di cattura post-combustione della CO₂ con fonti rinnovabili, ENEA, Ricerca di Sistema Elettrico, Settembre 2013.
- [19] Regione Puglia, Banca Dati Regionale del potenziale di biomasse in Puglia- Metodologia e Risultati, Novembre 2012.
- [20] Rovira A., Montes M.J., Varela F., Gil M., Comparison of Heat Transfer Fluid and Direct Steam Generation technologies for Integrated Solar Combined Cycles, *Appl Therm Eng* , 52 (2013) 264-274.

Biography

Roberto Carapellucci is an associate professor of Management of Energy Conversion Systems at the University of L'Aquila. He has about 30 years of teaching and research experience. He has been author of about 100 scientific papers on various topics, including advanced power generation, system modeling, renewable technologies, carbon capture. He is referee for several international peer-reviewed journals.